

Spokane Regional Health District (SRHD) conducts water adequacy reviews prior to the issuance of building permits for those projects in Spokane County that propose the use of a private water system to serve a building necessitating potable water. To determine if the water source is capable of supplying an adequate quantity of water, a pump test is required. This form is to be completed by a licensed water well driller or pump installer in accordance with the following criteria:

- 1. The proposed water source shall be pump-tested for a continuous four hours.
- 2. The pump test rate over the four-hour time period shall be provided in gallons per minute.
- 3. To be approved, the pump test rate must indicate a minimum water production rate of 1440 gallons per day per single-family residence and/or accessory building, or commercial building.
- 4. Include with this form all data collected regarding actual pumping rates during the pump test. Include draw down and recovery rates, if measured.

Property Owner:	
Parcel Number:	
Site Address:	
Water Source: Drilled Well Spring/Surface Water	Well Tag ID:
Pump Test Completed By: Company Name:	
Date of Pump Test:	
I certify that this water source was pump tested in accordance with the above criteria. The actual pump test rate was gallons per minute.	
Name of Licensed Well Driller or Pump Installer	
Signature of Licensed Well Driller or Pump Installer	Date

Spokane Regional Health District assures nondiscrimination in accordance with Title VI of the Civil Rights Act of 1964 and the Americans with Disabilities Act. To file a complaint or to request more information, reasonable accommodations, or language translations, contact 509.324.1501 or visit srhd.org.

